

## **Smoke Detector, Carbon Monoxide Detector, Fire Extinguisher Inspection Application**

- *Inspector(s) perform inspections Monday thru Friday between 9:00 AM – 4:00 PM*
- *Inspection fees are:*
  - *10 or more days prior to closing*                      \$ 50.00
  - *5 to 10 days prior to closing*                         \$ 100.00
  - *4 days or less prior to closing*                        \$ 165.00
- *Minimum of 1 **SMOKE DETECTOR** is required on each level of the house including the basement, unless original certificate of occupancy required more.*
- *One (1) **CARBON MONOOXIDE** is required on each level of the house that has bedrooms. (Example: if a person has 3 bedrooms on the second floor, then 1 carbon monoxide detector is required in the general area of the bedrooms, such as the hallway. Plug-In detectors are acceptable). We would recommend installing a detector on every level including the basement.*
- *Minimum of 1, **2A-10 BC type FIRE EXTINGUISHER** is required per residence, mounted on the wall in the kitchen or within 10 feet of the kitchen in plane site.*
- *House numbers are required per residence.*
- *A Certificate of Compliance will be issued upon successful completion of the inspection and the appropriate fee is paid*
- *Fill in the below information and leave at Fire Prevention Office. Mark Lime the Fire Official will contact you to schedule an inspection*

Home Owner's Name: \_\_\_\_\_

Street: \_\_\_\_\_

Telephone Number: \_\_\_\_\_

Alternate Number: \_\_\_\_\_

Real Estate Agency: \_\_\_\_\_

Agent: \_\_\_\_\_

Telephone Number: \_\_\_\_\_

Alternate Number: \_\_\_\_\_

## 1. SMOKE DETECTORS

- At a minimum, one smoke detector shall be located on each level of the residence, including the basement.
- The detectors should preferably be mounted to the ceiling.
- If a detector has to be mounted on a wall, it must be mounted 4 inches minimum and 12 inches maximum for the ceiling.
- Detectors must be 4 inches from any corner and a minimum of 3 feet for any air registers.
- **Any prewired / interconnected smoke and carbon detectors must be functioning, battery operated units CANNOT be substituted in lieu of getting the wired units functioning.**
- Please be sure to check the manufacturer's installation guide as well
- All battery-operated smoke alarms shall be powered by ten (10) year sealed batteries and shall be installed and shall be listed in accordance with ANSI/UL 217

## 2. CARBON MONOXIDE DETECTORS (CO)

- On each level that has bedrooms, detectors shall be installed within 10 feet of the bedrooms.
- They can be ceilings or walls with no height restrictions.
- Please be sure to check the manufacturer's installation guide as well.

## 3. FIRE EXTINGUISHERS

- At least one portable fire extinguisher shall be installed in all 1 and 2 family dwellings upon a sale or change of occupancy.
- Effective immediately the fire extinguisher shall be a **2A – 10 BC** (approximately 5 pounds) and no greater than 10 pounds. This shall be mounted within ten (10) feet of the kitchen and be visible.
- The extinguisher shall be charged, operable and **MOUNTED** in a visible location within 10 feet of the kitchen and not blocked by furniture, or behind a door or in a closet.

## 4. FEES

- The fee for the fire safety inspection is: **\$50.00**, if performed within the stated time frame (10 days prior to closing) as indicated on page 1 of this application, additional fees may be imposed.
- If a re-inspection is required if any of the above mandates fail it will result in an additional **\$ 40.00** fee for each additional re-inspection.
- Payment can be made by check, made out to the "**Kinnelon Fire Prevention Bureau**".

## 5. FAQ and Helpful Hints

- If you have a Fire Alarm System, you will be required to know how the system works, including password(s), alarm company phone number, how to silence and reset the system for us to inspect it. The alarm company must be notified that the system is being tested.
- Do not install detectors in attic unless it's a finished room. Variations of temperatures will cause erroneous smoke detector activation.
- Do not mount detectors in the stairway or at the top of the basement stairs.
- Do not mount detectors in kitchen as they often result in many nuisance alarms.
- Combination (Smoke and Carbon) detectors are permitted.
- **ALL DETECTORS 10 YEARS OR OLDER MUST BE REPLACED, PER MANUFACTURER'S RECOMMENDATIONS. REPLACEMENT SINGLE STATION BATTERY SMOKE DETECTORS SHALL BE 10 YEAR SEALED.**